ATTACHMENT 04



Re: DRC2015-00079 TENBROECK Coastal E -Referral, MUP (Cayucos) Michael Stoker to: Brandi Cummings



02/17/2016 08:36 AM

Cc: Cheryl Journey, Martin Mofield

Brandi.

Please find Buildings comments for DRC 2015-00079 below. Please let me know if you have any questions.

In regards to this preliminary review, a building permit is required. The drawings specify the work to be completed consists of a new single family dwelling of 2,019 sq. ft with an attached garage of 378 sq. ft. The project shall comply with current codes adopted by the County of San Luis Obispo (2013 California Building Standards Codes and Title 19 of the SLO County Codes).

While a thorough plan review will be conducted at time of building permit application, the following items are noted to assist design review;

- 1) Construction shall comply with the 2013 California Residential Code.
- 2) The design of the openings, projections, wall rating based on fire separation distance will need to be shown on the plans to comply with CRC Section 302, including Table 302.1(2) for buildings with sprinklers.
- Provide details for the stairs, handrails, and guardrails that comply with the California 3) Residential code.
- 4) Provide notes on the plans for the 'egress' windows to verify compliance with the California Residential code.
- 5) Provide plans which clearly show the structural design to verify compliance with the prescriptive requirements of the 2013 California Residential Code or any structural element not complying with the prescriptive requirements will need to be prepared by a California Licensed Design Professional (Architect or Engineer) justifying the structural design
- 6) Provide electrical plans with notes to show the location of the main electrical panel, sub-panels, receptacles, lights, switches, and smoke detectors and Co alarms to verify compliance with the 2013 California Electrical Code.
- Provide notes and information on the plans for the plumbing fixtures requirements, the 7) design of the waste lines, vents, and water lines will all need to comply with the 2013 California Plumbing Code.
- Energy calculation will need to be submitted to verify compliance with the 2013 8) California Energy Code.
- 9) The plans will need show compliance with the 2013 California Green Building Code and the County of San Luis Obispo's Green Building Ordinance.
- Fire sprinklers will be required for this project and will need to be submitted under a 10) separate permit application. Provide plans showing the design and layout for the sprinkler system.

Thanks

ATTACHMENT 04

Michael Stoker Building Division Supervisor, CASp 805.781.1543







SAN LUIS OBISPO COUNTY-

DEPARTMENT OF PLANNING AND BUILDING

Promoting the wise use of land - Helping to build season munities

JAN 2 6 2016

DATE:	1/25/2015
₹ 0:	Public works
EROM:	Brandi Cummings, DRC2015-00079, BCummings@co.slovea.us
	DESCRIPTION: DRC2015-00079 TENBROECK MUP, PROPOSED NEW SER (2019 ATTACHED GARAGE (378 SF), LOCATED AT 2788 RICHARD, CAYUCOS -204-032
	s letter with your comments attached no later than 14 days from receipt of this referral. ase respond within 60 days. Thank you.
PART 1 -	IS THE ATTACHED INFORMATION ADEQUATE TO COMPLETE YOUR REVIEW?
	YES (Please go on to PART II.) NO (Call me ASAP to discuss what else you need. We have only 10 days in which we must obtain comments from outside agencies.)
PART II -	ARE THERE SIGNIFICANT CONCERNS, PROBLEMS OR IMPACTS IN YOUR AREA OF REVIEW?
· .	YES (Please describe impacts, along with recommended mitigation measures to reduce the impacts to less-than-significant levels, and attach to this letter.) NO (Please go on to PART III.)
PART III -	INDICATE YOUR RECOMMENDATION FOR FINAL ACTION.
	Please attach any conditions of approval you recommend to be incorporated into the project's approval, or state reasons for recommending denial.
IF YOU HAVE "NO COMMENT," PLEASE SO INDICATE, OR CALL. See a Hacked	
l·2 Date	9.16 Pur Pomber 5271 Name Phone



SAN AHAS ARISHO COUNTY DEPARTMENT OF PUBLIC WORKS

Wade Horton, Director

County Government Center, Room 206 • San Luis Obispo CA 93408 • (805) 781-5252

Fax (805) 781-1229

email address: pwd@co.slo.ca.us



Date:

January 29, 2016

To:

Brandi Cummings, Project Planner

From:

Tim Tomlinson, Development Services

Subject:

Public Works Comments on DRC2015-00079, Tebbroeck MUP, Richard Av.,

Cayucos, APN 064-204-032

Thank you for the opportunity to provide information on the proposed subject project. It has been reviewed by several divisions of Public Works, and this represents our consolidated response.

Public Works Comments:

- A. PCC is not an acceptable driveway surfacing material within the County Road Right of Way.
- B. The project appears to not meet the applicability criteria for a Storm Water Management (it creates or replaces less than 2500 sf of impervious area). Therefore no Storm Water Control Plan is required.

Recommended Project Conditions of Approval:

Access

 At the time of application for construction permits, the applicant shall submit an application, fee and plans to the Department of Public Works to secure an Encroachment Permit to reconstruct the project access driveway in accordance with County B-1 series rural driveway standards.

<u>Drainage</u>

- 2. At the time of application for construction permits, the applicant shall submit complete drainage plans and report prepared by a licensed civil engineer for review and approval in accordance with Section 23.05.040 (Drainage) of the Land Use Ordinance.. The drainage plans and report shall also address the difference between the pre and post development 100 year flow off of the site.
- 3. At the time of application for construction permits, the applicant shall submit complete erosion and sedimentation control plan for review and approval in accordance with 22.52.120.